



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	3266-0057:0104
<b>CATEGORY:</b>	3266 - DOOR OPERATORS
<b>LISTEE:</b>	Stanley 65 Scott Swamp Road, Farmington, CT, 06032 Contact: Keenan, Marcus (407)963-5252 (860) 679-6409 Email: marcus.keenan@allegion.com
<b>DESIGN:</b>	Model "Magic-Access" pedestrian swing door operator. The unit is intended to be mounted above the door, secured to the building interior door frame, and the control assembly and motor enclosed by a metal cover. Refer to listee's data sheet for detailed product description and operational considerations.
<b>RATING:</b>	120 VAC, 50/60 Hz, 1.5 A
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, and UL label.
<b>APPROVAL:</b>	Listed as a door operator for swinging doors used on *3 hr fire-rated doors and assemblies. Authority having jurisdiction should be consulted prior to installation.
<b>NOTES:</b>	

\*Rev. 01-12-2005



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/07/2025**

**Listing Expires: 06/30/2026**

Authorized By: **Michael Huang**, Program Coordinator  
Fire Engineering & Investigations Division