



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	3265-0057:0103
CATEGORY:	3265 - POWER-OPERATED DOOR
LISTEE:	Stanley 65 Scott Swamp Road, Farmington, CT, 06032 Contact: Keenan, Marcus (407)963-5252 (860) 679-6409 Email: marcus.keenan@allegion.com
DESIGN:	Model DURA-GLIDE 5200 and 5300 exit doors. These units are available in single slide or bi-part. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	117 VAC, 60 Hz
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating and UL label.
APPROVAL:	Listed as non-rated sliding doors for use exit locations where fire-rated door is not required. Authority having jurisdiction should be consulted prior to installation.
NOTES:	

*Rev. 06-08-02



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/02/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division